

GUIDELINE SPECIFICATIONS

GORDON MILLENNIUM® DECORATIVE METAL COLUMN COVERS DIVISION 05 7500 or DIVISION 09 2000

Note To Specifier: Column Covers are a finished, decorative product and should be installed by tradesmen that are experienced in handling finished products. MILLENNIUM Column Covers shall be specified in Division 9-Finishes or Division 5-Metals.

PART 1-GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and General Provisions of the Contract, including General and Supplementary Conditions and Division 1 Specifications Sections apply to this Section.

1.2 SUMMARY

- A. This section includes MILLENNIUM Metal Column Covers as shown on drawings.
- B. Related Sections include the following:

1.3 SUBMITTALS

- A. Manufacturer's Literature and Data:
 - 1. Product Data: Submit manufacturer's technical data and brochures for each type of column cover required.
- B. Shop Drawings:
 - 1. Shop drawings shall show dimensions, sizes, thickness, alloys, tempers, finishes, joining, attachments, and relationship of adjoining work.
- C. Samples:
 - 1. Samples shall include 5" x 7" piece of each type of metal and finish as specified.
- D. Certification:
 - 1. Submit certificates from manufacturer of panels attesting that products comply with specified requirements including finish as specified.
- E. Qualification Data:
 - 1. Firms specified in "Quality Assurance" Article must demonstrate their capabilities and experience by including lists of completed projects with project names and addresses, names and addresses of architects and owners, and other information specified.

1.4 QUALITY ASSURANCE

- A. Manufacturer: Firm with manufacturing and delivery capacity required for the project, shall have successfully completed at least ten projects within the past five years, utilizing systems, materials and techniques as herein specified.

- B. Fabricator must own and operate its own manufacturing facilities for all metal components. "Stick Built" or "Kit of Parts Systems" consisting of components from a variety of manufacturers will not be considered or accepted.
- C. Manufacturer/Fabricator must own and operate its own Painting and Finishing facility to assure single source responsibility and quality control.

1.5 DELIVERY, STORAGE & HANDLING

All material shall be protected during fabrication, shipment, site storage and erection to prevent damage to the finished work from other trades. Store wall panels inside a well-ventilated area, away from uncured concrete and masonry, and protected from weather, moisture, soiling, abrasion, extreme temperatures, and humidity.

PART 2 – PRODUCTS

2.1 MANUFACTURER

- A. MILLENNIUM[®] Column Covers shall be manufactured by Gordon Interior Specialties Division, Gordon, Inc., 5023 Hazel Jones Road, Bossier City, LA 71111, (800) 747-8954, Fax (800) 877-8746, www.gordoninteriors.com, sales@gordoninteriors.com.
- B. The listed manufacturer shall not be construed as closing specifications to other prospective manufacturers, but rather as establishing a level of quality in a metal system. Other systems may be submitted for approval as provided for in the specification at least 10 working days prior to submission of bids. Companies desiring to submit a proposal shall submit all descriptive information of the system proposed including photographs and shop drawings of at least three projects similar in detail and scope.

2.2 MATERIALS

- A. MILLENNIUM Metal Column Covers shall be a complete Gordon, Inc. system (N-gage^{TM1} system). All secondary posts, anchors, clips and extrusions are to be provided as indicated per shop drawings. No exposed fasteners are allowed.
- B. General: Provide metals free from surface blemishes where exposed to view in finished unit. Surfaces exhibiting pitting, seam marks, roller marks, stains, discolorations, or other imperfections on finished units are not acceptable. All metal shall be of the highest grade, commercial type.
- C. Material shall be one of the following:
 - 1. Aluminum, 3003-H14, minimum .063" (14 Gauge) thickness [ASTM B 209 (ASTM B 209M)]
 - OR**
 - 2. Galvanized Steel, 18 gauge, G90 hot dipped galvanized, extra smooth spangle (ASTM A 653/A 653M-99)

2.3 FABRICATION

- A. Height of Column Covers shall be up to 10'-0" without horizontal joints.

- B. Column Covers shall have either a butt joint, snap-in tee joint, horizontal reveal joint, or vertical reveal joint, as shown on the architectural drawings. All other details including base and ceiling details shall be fabricated in accordance with the architectural drawings.
- C. Column Covers shall be manufactured true to geometry as shown on plan view of the architectural drawings with manufacturing tolerances.
- D. N-gage™¹ system:
 - 1. Covers shall be fabricated with concealed return flanges, factory welded to MILLENNIUM at the vertical joints for structural strength. Each column cover shall be reinforced at the top and bottom with gussets.
 - 2. Engagement N-gage clips shall be provided and factory attached to the column covers at specified intervals to allow for complete accessibility without tools or exposed fasteners. A clearance of ¼" is required at the top for installation.
 - 3. In those cases where access is restricted to authorized personnel, a locking method at the top will be provided.
 - 4. All covers shall be removable, demountable, and re-usable without exposed fasteners.

2.4 FINISHES

- A. General: Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations relative to applying and designating finishes.
- B. Finish designations prefixed by AA conform to the system established by the Aluminum Association for designating aluminum finishes.
- C. Factory applied ACROGUARD® High Performance Powder Coat finish.
 - 1. All Column Covers shall receive a micro-etched pretreatment prior to receiving an electrostatically applied ACROGUARD® High Performance Powder Coat finish.
 - 2. All exposed surfaces must be coated. Finish shall be cured and oven baked to insure paint adhesion and uniform surface hardness.
 - 3. Paint to be selected from standard colors (or approved custom color).
- D. Factory applied ACROGUARD®-UVX Durable Exterior Powder Coat finish.
 - 1. All Column Covers shall receive a micro-etched pretreatment prior to receiving an electrostatically applied ACROGUARD®-UVX Powder Coat finish.
 - 2. All exposed surfaces must be coated. Finish shall be cured and oven baked to insure paint adhesion and uniform surface hardness.
 - 3. Paint to be selected from standard colors (or approved custom color).
- E. High Performance Organic Coating Finish: AA-C12C42R1x (Chemical Finish: cleaned with inhibited chemicals; Chemical finish: acid chromate-fluoride-phosphate)

conversion coating; Organic Coating: as specified below). Prepare, pre-treat, and apply coating to exposed metal surfaces to comply with coating and resin manufacturer's instructions.

1. Fluoropolymer Coating System: Manufacturer's standard 2, 3, or 4 -coat thermo-cured system composed of specially formulated inhibitive primer, fluoropolymer color coat, and clear fluoropolymer topcoat, with both color coat and clear topcoat containing not less than 70% polyvinylidene fluoride resin by weight; complying with AAMA 605.2.
2. Aluminum shall receive a factory applied and baked finish of 70% polyvinylidene fluoropolymer (PVDF) resin (Kynar® or Hylar®) OR If aluminum is to be field painted (Floated System), it should receive a factory-applied primer paint pre-treatment in Gordon Standard White (VX-132).

Kynar® is a registered trademark of ATOFINA.

Hylar 5000® is a registered trademark of Ausimont Montedison Group.

3. Color & Gloss: To be selected from manufacturer's standard available.

F. Apply finish to exposed surfaces of MILLENNIUM® Column Covers after fabrication.

PART 3-EXECUTION

3.1 INSTALLATION

- A. Install MILLENNIUM Column Covers in accordance with manufacturer's written installation instructions and shop drawings.
- B. Column Covers shall be erected plumb, level, square, true to line, securely anchored, and in proper alignment and relationship to work of other trades. Exterior joints are to be sealed by installer with backer rods and sealant.
- C. Column Covers shall be inspected before installation to be free from dents, scratches, and other defects.

3.2 CLEANING

- A. Removal of protective covering shall occur immediately after installation to prevent adhesive transfer.
- B. Clean all surfaces following installation.
- C. Maintenance per manufacturer's finish maintenance instructions.

3.3 PROTECTION

- A. Protection of column covers from damage by other trades after installation to be provided by general contractor.

3.4 GENERAL RESPONSIBILITY

- A. Variation from specification: Any variation from this specification resulting in additional cost to any other contractor or subcontractor on this project shall be the sole financial responsibility of the contractor for the work of this section.