

GORDON, INC. METAL WALL PANEL SYSTEMS

SECTION 09 84 00

PART 1 – GENERAL

1.01 SECTION INCLUDES:

- A. This section includes Metal Wall Panel Systems and components as shown on the Architectural Drawings.
- B. Related sections include the following: (list applicable sections).

1.02 RELATED DOCUMENTS/SECTIONS:

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions.
- B. Division 1 Specification sections apply to work of this Section.
- C. Finish Schedule or Finish Legend applies to work of this Section.

1.03 REFERENCES:

- A. GENERAL
 - 1. Comply with applicable requirements of the following, except where more stringent requirements are indicated by building codes.
- B. ASTM (American Society for Testing and Materials)
 - 1. B209 Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate
 - 2. E84 Standard Test Method for Surface Burning Characteristics of Building Materials
- C. The Aluminum Association Standards and Data
- D. LEED® Requirements as indicated (LEED® is a registered trademark of the USGBC):
 - 1. Materials and Resources
 - a. MR Credit 4 – Recycled Content
 - b. MR Credit 5 – Regional Materials
 - 2. Indoor Environmental Quality
 - a. IEQ Credit 4.2 – Low Emitting Materials, Paints
 - 3. Innovation in Design
 - a. ID Credit 1 – Exceptional Acoustical Performance

1.04 DESIGN/PERFORMANCE REQUIREMENTS:

- A. All components of the Metal Wall Panel System shall be provided by one (1) Manufacturer to ensure single source responsibility and quality control.

1.05 SUBMITTALS:

- A. Submission must be made within ten (10) working days of the General Contract Award to avoid project delay.

- B. Product Data: Submit Manufacturer's technical data and brochures for each type of metal Wall Panel required.
- C. Shop Drawings shall show dimensions, sizes, thickness, finishes, joining, attachments, and relationship to adjoining work.
- D. Samples:
 - 1. Samples shall include a 5" x 7" piece of each type of metal and finish as specified, and extrusions if required.
- E. Certification: Submit certification from Manufacturer of Wall Panels attesting that products comply with specified requirements including finish as specified.
- F. Qualification Data:
 - 1. Firms specified in "Quality Assurance" Article must demonstrate their capabilities and experience by including lists of completed projects with project names and addresses, names and addresses of Architects and owners, and other information specified.
- G. Warranty:
 - 1. Provide product warranty for one (1) year from date of material shipment.

1.06 QUALITY ASSURANCE:

- A. Manufacturer: Firm with manufacturing and delivery capacity required for the project, shall have successfully completed at least ten (10) projects within the past five (5) years, utilizing systems, materials, and techniques as herein specified.
- B. Fabricator must own and operate its own manufacturing facilities for all metal components. "Stick Built" or "Kit of Parts Systems" consisting of components from a variety of Manufacturers will not be considered or accepted.
- C. Manufacturer/Fabricator must own and operate its own Painting and Finishing facility to assure single source responsibility and quality control.

1.07 PRODUCT DELIVERY, STORAGE AND HANDLING:

- A. All materials shall be protected during fabrication, shipment, site storage, and erection to prevent damage from other trades. Store Wall Panels and components inside a well-ventilated area, away from uncured concrete and masonry, and protected from the weather, moisture, soiling, abrasion, extreme temperatures, and humidity.

1.08 SEQUENCING:

- A. Substitute Products: Alternate proposals for substitute products will not be accepted unless approval is issued in addenda.
- B. Contract Execution: Submittals shall be completed and approved prior to award of subcontract for system components.
- C. Manufacturer's Production Schedule: Sub-contract for the work of this section shall be planned to allow sufficient time for Manufacturer's production and delivery scheduling.

1.09 WARRANTY:

- A. Furnish Manufacturer's:
 - 1. Warranty that materials furnished will perform as specified for a period of not less than one (1) year from date of material shipment when installed in accordance with Manufacturer's recommendations.

PART 2 - PRODUCTS

2.01 MANUFACTURERS:

- A. Acceptable System: Metal Wall Panel Systems shall be manufactured by Gordon, Inc. For all inquiries contact, Gordon, Inc., 5023 Hazel Jones Road, Bossier City, LA 71111, (800) 747-8954.
- B. The listed Manufacturer shall not be construed as closing specifications to other prospective Manufacturers, but rather as establishing a level of quality in a metal system. Other systems may be submitted for approval, as provided for in the specifications at least ten (10) working days prior to submission of bids. Companies desiring to submit a proposal shall submit all descriptive information of the system proposed including photographs and Shop Drawings of at least three (3) projects similar in detail and scope.

2.02 PRODUCT CONSTRUCTION:

- A. Metal Wall Panel System shall be a complete Gordon, Inc. system. All secondary framing, anchors, clips, and extrusions are to be provided as a complete package of this work. No exposed fasteners for metal closures are allowed.
- B. Materials:
 - 1. Metal Panels:
 - a. Metal Wall Panels shall be made from aluminum sheet, 3003 alloy (choose thickness: 0.063", 0.090", 0.125") thick OR
 - b. Metal Wall Panels shall be made from stainless steel sheet Type 304 (choose thickness: 14-24) Gauge, with (choose type: #4 brushed finish, #8 polished finish, mechanical finish, textured, or embossed mechanical finish).
 - c. If Wall Panels are perforated, perforations can be selected from the Manufacturer Perforation Selector on the website.
 - 2. Mounting Accessories:
 - a. For surface mounting to structural wall, furnish Z Clips in extruded aluminum.
 - 3. Optional Acoustical Media if Wall Systems are Perforated:
 - a. Acoustical encapsulated insulation pads OR
 - b. Nonwoven acoustical fabric applied to the concealed surface.
 - 4. General: Provide metals free from surface blemishes where exposed to view in finished unit. Surfaces exhibiting pitting, seam marks, roller marks, stains, discolorations, or other imperfections on finished units are not acceptable. All metal shall be of the highest grade, commercial type.

2.03 FINISHES:

- A. Finishes

1. Metal Wall Panels (aluminum) shall receive 5-stage pretreatment with dried-in-place conversion coating prior to receiving an electrostatically applied AAMA 2604 or AAMA 2605 compliant powder coating finish.
 2. All cut edges, including perforated holes, must be coated. Finish shall oven baked to ensure complete curing, paint adhesion, and uniform surface hardness.
 3. Paint color to be selected from Gordon Inc.'s list of Standard Colors (Custom Colors also available).
- B. Panels may have a factory-applied wood-look finish:
1. Laminated Wood-Look Films – Series 1
 2. Laminated Wood-Look Films – Series 2
 3. Wood-Look Paints

2.04 FABRICATION:

- A. Height of Wall Panels shall be up to 12'-0" without horizontal joints. (Note that the maximum size of an un-fabricated sheet is 60" in width).
- B. Wall Panels shall have either a closed or reveal vertical joint, as shown in the Architectural Drawings. All other details, including base and wall details, shall be fabricated in accordance with the Architectural Drawings.

PART 3 - EXECUTION

3.01 EXAMINATION:

- A. Examine building structure scheduled to receive wall system for unevenness or irregularities that would affect quality and execution of work.
- B. Wall Panels shall be erected plumb, level, square, true to line, securely anchored, and in proper alignment and relationship to work of other trades. Exterior joints are to be sealed by installer with backer rods and sealant.
- C. Wall Panels shall be inspected before installation to be free from dents, scratches, and other defects.

3.02 PREPARATION:

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the Manufacturer to achieving the best result for the project conditions.

3.03 INSTALLATION:

- A. General: Comply with Manufacturer's printed instructions, governing regulations for Seismic Codes, and with the Ceiling & Interior Systems Construction Association standards applicable to work.
- B. Space Enclosure: Do not install any work until space is enclosed and weatherproofed, wet-work in space is completed and nominally dry, work above ceilings is complete, and temperature and humidity shall be continuously maintained at values near those of final occupancy.

3.04 CLEANING:

- A. Follow Manufacturer's cleaning instructions for specified finish.

3.05 PROTECTION:

- A. Procedures: Protection of Metal Wall Panel Systems from damage by other trades after installation to be provided by General Contractor.
- B. Damage to Finished Work: Finished units shall be without damage. Damage shall be repaired by the Contractor at the expense of the party damaging the material, as in accordance with the contract requirements.

END OF SECTION